

BUILDING SAFETY CERTIFICATE

NO..25/AE II/08/5/2024

Dated: 02/01/2024

Certified that the **Saraswati Shiksha Mandir Senior Secondary School** (Name of the building or premises) at **Gram Bharti Partosh, Amethi, Uttar Pradesh** (address) comprised of Nil basements and Ground Floor Plus 1 Floor in one Building and Ground Floor plus 1 Floor in another Building owned/ occupied by **Saraswati Shiksha Mandir Senior Secondary School** (name of the Institution) have complied with the Building Bye Laws in accordance with rule of State/UT and incorporate the provisions of building safety as specified in National Building code 2005, 2016 and as amended thereafter and has been verified by the concerned officer on. 02/1/2024.....(date of Inspection) in the presence of

Mr. Vivek kumar Sharma (Name and address of Manager / Secretary/Principal or his Representative) and that the said above building/premises is safe and fit for running School with effect from 02/1/2024 for a period of 2.0 years in accordance with rules. As per 18 point check list attached.

Issued on 02/1/2024 at 12.00 P.M. by

*Strike out whichever is not applicable.


Assistant Engineer

Signature with Seal:  Provincial Division P.W.D.
Amethi

Authority: G.P. P.W.D.

Designation: Asst. Engineer P.D. P.W.D. Amethi

To

Saraswati Shiksha Mandir Senior Secondary School
Gram Bharti Partosh, Amethi, Uttar Pradesh
(Name & Address of the Institution)

ENDORSEMENT

The No Objective Certificate issued by department stand cancelled and annulled due to
.....
.....(reason to be

(Name of designation of the authorized signatory)



सरस्वती शिक्षा मंदिर सीनियर सेकेण्ड्री स्कूल

ग्रामभारती परतोष जनपद-अमेठी उ0प्र0

एन0बी0सी0 के अनुसार विद्यालय में सुरक्षा विशेषकर सुरक्षा से सम्बन्धी चेक लिस्ट

(क)दो मंजिला (भूतल+तल)भवनों हेतु चेकलिस्ट

क्र0	सुरक्षा सम्बन्धी तकनीकी विन्दु	जॉच संख्या
1	क्या भवन एक मंजिला है अथवा दो मंजिला ?	है
2	क्या भवन हेतु भूमि न्यूनतम क्षेत्रफल 0.4 हेक्टेअर(4000 वर्गमीटर) है?	6860 मी ²
3	क्या भवन में पार्किंग के लिए सुरक्षित व्यवस्था है ?	हाँ
4	क्या भवन का ओरियन्टेशन ऐसा है कि पर्याप्त प्रकाश एवं हवा का सर्कुलेशन है ?	हाँ
5	क्या मुख्य पहुँच मार्ग (Approach Road) की चौड़ाई न्यूनतम 12 मीटर है ?	हाँ
6	क्या भवन की छत आर सी सी की बनी है ? यदि नहीं तो क्या छत निर्माण में ज्वलनशील सामग्री तो प्रयोग में नहीं लायी गयी ?	R.C.C. + R.B. छत
7	क्या भवन की दीवारें ईट या पत्थर की सीमेण्ट मसाले से बनी हैं?	हाँ
8	क्या भवन की दीवारों/छतों में क्रैक है ?	नहीं
9	क्या कक्षाओं की छतों की ऊँचाई फर्श से न्यूनतम 3.6 मीटर (ठण्डे क्षेत्रों में 3.0 मीटर) है ?	है-1
10	क्या विद्यालय के मुख्य प्रवेश द्वार (बाउण्ड्री वाल गेट) की चौड़ाई 4.00 एवं ऊँचाई 3.66 मीटर है?	है-1
11	क्या खिड़कियों में लकड़ी का क्षेत्रफल कक्षा के फर्श क्षेत्रफल का न्यूनतम 10 प्रतिशत है ? खिड़कियों में लकड़ी का प्रयोग तो नहीं किया गया है?	हाँ
12	क्या कक्षा में न्यूनतम दो दरवाजे हैं ?	हाँ
13	क्या कक्षा के दरवाजे की न्यूनतम माप (चौड़ाई 1.0 मी0 ऊँचाई 2.0 मी0) है?	है-1
14	क्या एम मंजिल से अधिक ऊँचे भवन में जीने की चौड़ाई न्यूनतम 1800 मिमी0, ट्रेड 350 मिमी0 तथा राइजर 175 मिमी0 है ?	1500 मिमी0 चौड़ाई
15	क्या भवन के कक्षाओं से जीने की अधिकतम दूरी 22.50 मीटर है ?	हाँ
16	क्या भवन में रसोईघर मुख्य भवन से अलग है ?	नहीं
17	क्या भवन में मुख्य द्वार के अतिरिक्त आकस्मिक निकास की व्यवस्था है ?	है-1
18	क्या भवन में उचित स्थान पर अग्निशामक यंत्र लगे हैं ?	है-1

अवर अभियन्ता

प्रान्तीय खण्ड लो0नि0 विभाग

अमेठी

सहायक अभियन्ता

Assistant Engineer

Provincial Division P.W.D.

Amethi

अमेठी